


Serial No. 804,044
Filing Date 26 February 1997
Inventor Ronald Sheinson
Alexandria Maranghides

NOTICE

The above identified patent application is available for licensing. Requests for information should be addressed to:



DTIC QUALITY INSPECTED 4

OFFICE OF NAVAL RESEARCH
DEPARTMENT OF THE NAVY
CODE OCCC3
ARLINGTON VA 22217-5660

19970422 104

ORIGINAL

WATER SPRAY COOLING SYSTEM FOR EXTINGUISHMENT AND POST FIRE SUPPRESSION OF COMPARTMENT FIRES

Background of the Invention

1. Field of the Invention

The present invention relates to generally to the control and extinguishment of fires, and more particularly, to the control and extinguishment of compartment fires.

2. Description of the Background Art

Compartment fires, unlike open air fires, have limited access to the outside environment. This limited access restricts the transfer of heat and fumes with the environment. Therefore, compartment fires are often extremely hot and may quickly contaminate the affected compartment with dangerous levels of toxic fumes. Additionally, compartment fires have the potential to spread quickly throughout the compartment. Moreover, the restricted venting of a compartment to the outside, while it allows sufficient oxygen to maintain the fire, may prevent combustible fuel in the compartment from cooling sufficiently quickly to prevent post suppression reignition. Thus, compartment fires must be rapidly and thoroughly extinguished to minimize loss of life and/or property.

1 Many compartments made for housing combustibles include a fire
2 suppression system. The most widely accepted fire suppression
3 system for fires uses fluorinated bromohydrocarbons such as Halon™.
4 Halon™ performs exceptionally well at fully extinguishing fires and
5 preventing post suppression reignition, with few toxic byproducts
6 being generated during fire suppression. Nevertheless, the
7 manufacture of fluorinated bromohydrocarbons has been banned
8 because of the threat they pose to the ozone layer. Thus, other
9 gaseous fire suppression agents have been substituted for Halon™.

10 Generally, these other gaseous fire suppression agents have
11 lacked the qualities of Halon™. Compared with Halon™, many exhibit
12 poor fire suppression efficiency, poor heat transfer, and poor
13 reignition suppression. Because of their decreased efficiency,
14 larger amounts of these substitute agents must be stored in fire
15 suppression systems. This requirement for larger amounts of
16 gaseous fire suppression agents increases the expense of the system
17 and the space it occupies. Additionally, because of their
18 relatively decreased fire suppression efficiency, more of these
19 gaseous fire suppression agents must react with the flame to break
20 the chain reaction of combustion and suppress the fire.
21 Unfortunately, this increased reaction of gaseous fire suppression
22 agents with the flame produces increased quantities of toxic and
23 corrosive byproducts. Further, the cooling ability of many
24 substitute gases is significantly less than that of Halon™.
25 Consequently, the risk of post suppression reignition increases.

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

Water mists have also been used for the suppression of compartment fires. While these system have reduced toxicity problems compared with gaseous fire suppression agents, they have several drawbacks. Because water mist does not behave completely like a gas, it may not reach all areas within a compartment. Thus, great care must be taken to assure that all areas within the compartment may be accessed by the spray. Also, water mist must be sprayed under extremely high pressures of about 250 psi or more. These pressures require specialized high pressure plumbing, thus increasing the expense of the system and limiting the ability to retrofit a previously existing compartment with a water mist system. Also, water mist systems require large amounts of water to extinguish a fire. The large weight and bulk of water, compared to gaseous fire suppression agents, makes storing the required large amounts of water troublesome. Because of these storage problems, designers may reduce the safety margin of these systems to minimize the amount of water that must be stored. Current systems which employ water and a gaseous propellant require high pressure and large amounts of both water and gaseous propellant.

Summary of the Invention

Accordingly, it is an object of this invention to suppress compartment fires without requiring the use of gaseous fluorinated bromohydrocarbon fire suppression agents.

1 It is another object of the present invention to suppress
2 compartment fires while minimizing the generation of toxic fumes
3 from the resulting from use of gaseous fire suppression agents.

4 It is a further object of the present invention to suppress
5 compartment fires without the use of large amounts of water, and
6 without the use of highly pressurized water.

7
8 These and additional objects of the invention are accomplished
9 by a system in which a water droplets are initially sprayed into a
10 compartment fire for a sufficient amount of time to greatly reduce
11 the ambient compartment temperature. The amount of water is not
12 sufficient to extinguish the fire. After water has significantly
13 reduced the ambient compartment temperature, the compartment is
14 flooded with a gaseous suppression agent.

15
16 **Brief Description of the Drawings**

17
18 A more complete appreciation of the invention will be readily
19 obtained by reference to the following Description of the Preferred
20 Embodiments and the accompanying drawings in which like numerals in
21 different figures represent the same structures or elements,
22 wherein:

23 Fig. 1 shows the layout of a facility in which an embodiment
24 of the present invention was tested.

1 Fig. 2 shows the measured temperatures from the aft
2 thermocouple tree during a test of a prior art fire suppression
3 method.

4
5 Fig. 3 shows the measured temperatures from the aft
6 thermocouple tree during a test of simultaneous water spray and
7 introduction of gaseous fire suppression agent.

8
9 Fig. 4 shows measured temperatures from the aft thermocouple
10 tree during a test of a method of fire suppression according to an
11 embodiment of the present invention wherein the water spraying
12 begins before and ends shortly after discharge initiation of fire
13 suppression agent, and then begins again several minutes after
14 initial discharge of the gaseous fire suppression agent.

15
16 Fig. 5 shows the effect of water spraying on compartment
17 temperature after fire suppression.

18
19 Fig. 6 shows the effects of water spraying, prior to discharge
20 of a gaseous fire suppression agent, on compartment HF levels.

21
22 Fig. 7 shows the scrubbing performance of water spraying
23 initiated after discharge of the gaseous fire suppression agent.

Description of the Preferred Embodiments

1
2
3 Unlike water mist extinguishing systems, the present invention
4 user water not to extinguish the fire, but to enhance compartment
5
6 *uses* reduce fire/agent decomposition byproducts generation,
7 ated decomposition byproducts, enhance reignition
8 and facilitate compartment reclamation procedures.

9 present invention uses water for other than fire
10 extinguishment, the water need not be applied as a mist under high
11 pressure. Instead, before application of the gaseous fire
12 suppression agent, water is sprayed onto the compartment fire at a
13 pressure of about 40 to about 150 psi. More typically, the water
14 is sprayed under a pressure of about 40 to about 100 psi. Most
15 typically, a water pressure of about 40 to about 80 psi will be
16 employed. Typically, the present invention uses a water spray in
17 which a majority of the water droplets have a diameter of about 100
18 to about 200 μm .

19 The pressure, droplet size, and coverage determine the
20 application rate of water. Typically, this application rate is
21 about 0.0029 to about 0.009 gallons per minute per cubic foot
22 (ggm/ft^3 or $\text{g}/\text{min}/\text{ft}^3$) compartment space.

23 *g p m*
24 *g p m / ft³* the water is discharged downward onto the fire from
25 ally, this nozzle may extend at or just below the
compartment, or it may be positioned along a
compartment. Preferably, the water nozzles are

1 positioned above the level of any combustibles in the compartment.
2 Also, even though the ultimate direction of water discharge is
3 downward (due to the influence of gravity), the initial direction
4 of discharge is not critical provided that the nozzles provide
5 reasonably uniform coverage of the compartment. Throughout the
6 present specification and the claims that follow, any reference to
7 a downwardly directed discharge or spray of water refers to the
8 ultimate, not the initial, direction of discharge, unless otherwise
9 stated explicitly.

10 Before the fire suppression agent is applied, sufficient water
11 is sprayed in the compartment to reduce the ambient compartment
12 temperature to below 100°C. (In accordance with art-recognized
13 terminology, the term "ambient compartment temperature" does not
14 include the flame or the immediately surrounding air, which will
15 obviously be much hotter than the remainder of the compartment.)
16 Typically, no more than the amount of water needed to reduce the
17 ambient compartment temperature to between about 100°C and about
18 20°C is sprayed before application of the gaseous fire suppression
19 agent. More typically, only the amount of water needed to reduce
20 the ambient compartment temperature to between about 60° and about
21 35° is sprayed before application of the gaseous fire suppression
22 agent. Most often, only the amount of water needed to reduce the
23 ambient compartment temperature to between about 60° and about 40°
24 is sprayed before application of the gaseous fire suppression
25 agent.

1 This cooling of the compartment before addition of the gaseous
2 fire suppression agent greatly reduces the generation of toxic
3 byproducts, such as HF, from the reaction of the gaseous fire
4 suppression agent with the flame. Continuation of the water spray
5 after application of the gaseous fire suppression agent scrubs the
6 compartment, further reducing the concentration of gaseous
7 byproducts.

8 Typically, best results are obtained by continuing the water
9 spraying, at the application rates, pressures, and droplet sizes
10 taught herein, after the initial discharge of the gaseous fire
11 suppression agent until either discharge of the gaseous fire agent
12 is complete or until the fire has been extinguished, whichever is
13 longer.

14 For compartment fires of a typical size and temperature, such
15 as that described in the EXAMPLES section below, water spraying
16 will usually occur over a period of up to about three minutes
17 (inclusive), and at least about 20 sec, before initial discharge of
18 the gaseous fire suppression agent until up to about 2 minutes
19 (inclusive), and most often 10 or more seconds, after initial
20 discharge of the gaseous fire suppression agent.

21 Obviously, nozzle coverage should for the water spray should
22 be designed to provide the most uniform compartment cooling
23 practical. The optimum number of nozzles per area of floor space
24 will depend on nozzle design, the number of tier of nozzles per
25 unit compartment height, and the desired safety margin. The design

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 of the water nozzle is not critical so long as the water nozzle
2 supplies appropriately size water droplets at the pressures and
3 water flow rate ~~by~~ the present invention, as well
4 as reasonably *appropriate size* in the selected distribution of
5 nozzles within *or*

6 The water *appropriately sized* in the method of the present
7 invention may be tiered. In one typical design, with one nozzle
8 per 55 ft² floor space and 120 degree full cone water mist nozzles,
9 one tier for a compartment height of 30 ft or less was sufficient.

10 Generally, for the present invention, water spraying for a
11 period of from 1 min before to 1 min after initial discharge of the
12 gaseous agent uses a total of about 2.5 to about 9 gallons per 1000
13 ft³ of compartment volume. An additional water spray just before
14 venting further reduces the concentration of gaseous byproducts and
15 also minimizes the risk of reignition. This volume will vary
16 depending upon the actual time the H₂O is applied. Actual time of
17 application will vary depending on flame temperature, water
18 availability, and concerns over collateral damage.

19 Also, depending upon water availability and concerns over
20 collateral damage, additional water may be sprayed after
21 extinguishment of the fire to both further reduce the possibility
22 of reignition upon venting and to further scrub the compartment of
23 toxic combustion byproducts. Additionally scrubbing, however, is
24 not required.

25 The water spray system used in the present invention can rely

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 upon water from a standard water tank, a standard water main, a
2 standard firemain, or a standard standpipe. Thus, the system may
3 be easily retrofit into existing fire suppression systems.

4 Although not necessary, water sprayed in accordance with the
5 present invention may include additives, such as alkali carbonates,
6 salts, and foaming agents, to enhance fire suppression performance.
7 Nevertheless, the inclusion of these additives may unnecessarily
8 increase the complexity and expense of the fire suppression system
9 of the present invention.

10 Any gaseous fire suppression agent may be used in conjunction
11 with the present invention. Typical gaseous fire suppression
12 agents include perfluorobutane (C_4F_{10}); dichlorotrifluoroethane
13 (4.75%) ($CHCl_2CF_3$) / chlorodifluoromethane
14 (82%) ($CHClF_2$)/chlorotetrafluoroethane (9.5%) ($CHClFCF_3$)/isopropenyl-
15 1-methylcyclohexane (3.75%); chlorotetrafluoroethane ($CHClFCF_3$);
16 pentafluoroethane (CHF_2CF_3); heptafluoroethane (CF_3CHFCF_3);
17 trifluoromethane (CHF_3); hexafluoropropane ($CF_3CH_2CF_3$);
18 trifluoroiodide (CF_3I); argon (52%) / argon
19 (40%) / carbon dioxide (8%); and nitro *heptafluoropropane* (50%) (all
20 percents stated by volume throughout *(NOT ethane)* and claims,
21 unless otherwise stated). Appli eous fire
22 suppression agent begins just after the ambient compartment
23 temperature cools to the required extent by the water, and is
24 continued until the fire is extinguished.

25 The discharge of the water spray and the gaseous fire

1 suppression agent may be controlled automatically, for examples via
2 temperature sensors and/or timers (with or without microprocessor
3 control) or manually. Obviously, the present invention requires
4 that the water spray and gaseous agent can discharged independently
5 of each other.
6

7 Having described the invention, the following examples are
8 given to illustrate specific applications of the invention
9 including the best mode now known to perform the invention. These
10 specific examples are not intended to limit the scope of the
11 invention described in this application.
12

13 EXAMPLES 14

15 The test compartment 10 aboard the ex-USS SHADWELL was located
16 at the 4th deck upper and lower levels between Frames 22 and 29
17 with catwalks on both levels (Fig. 1). The approximate dimensions
18 of the space were 8.5 m (28 ft) long from frames 22 to 29, 6.1 m
19 (20 ft) high from keel to 3rd deck and 8.5 m (28 ft) wide (port to
20 starboard) at frame 29 narrowing to 7 m (23 ft) wide at frame 22.
21 The enclosed volume was approximately 395 m³ (13,950 ft³). Lower
22 and upper horizontally disposed platforms (solid plates with
23 openings therein) 18 and 19, respectively, partitioned this volume
24 into bilge 20 and lower and upper tiers 22 and 23, respectively.
25 Lower platform 19 also included grating 24 to permit ready drainage

1 into bilge 20. With the LM-2500 gas turbine mock-up 11 occupying
2 approximately 7% of the air space, the adjusted compartment volume
3 became 370 m³ (13,000 ft³). The primary supply and exhaust
4 ventilation system (not shown) in the test space provided
5 approximately 55 air changes per hour. A second exhaust system,
6 the acid exhaust system (not shown), was used for venting
7 decomposition products.

8 The nomenclature used to identify a location in the test
9 compartment, e.g., (4-22-3: 0.6m), was level first (4 or 5 for
10 upper or lower) followed by the frame number (22-29) and then by
11 its athwart ship position (0-4). Zero (0) refers to centerline, 1
12 and 3 to starboard, and 2 and 4 to port, with 3 and 4 being
13 farthest away from centerline. In general, the height was
14 expressed in meters from the level's deckplate. Thermocouple tree
15 heights, however, were all measured from the lower level deckplate.
16

17 AGENT AND WATER SPRAY COOLING SYSTEMS

18 The two gaseous agent extinguishing systems used (Fig. 1) in
19 the tests described below were designed by MPR with the computer
20 code TFA. Bird et al., *Proceedings of the Halon Options Technical*
21 *Working Conference*, May 3-5, 1994, Albuquerque, NM, pp. 95-103, the
22 entirety of which is incorporated herein by reference for all
23 purposes. Each system, one for HFP and one for Halon 1301,
24 consisted of four discharge nozzles 12 divided into two tiers.
25 These two systems were disposed parallel, alongside and in close

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 proximity, to each other, are represented in Fig. 1 as gaseous
2 agent delivery system 13 (for simplification, only one set of four
3 nozzles shown in Fig. 1).

4 The Halon 1301 system used standard Navy 4 hole (horizontal-
5 cross) nozzles. The HFP discharge system used similar nozzles.
6 However, because of the increased agent volume required to deliver
7 effective concentrations of HFP, the nozzle diameters were larger
8 than the standard Navy. All nozzles in all tests were oriented in
9 the forward / aft position.

10 The Water Spray Cooling System (WSCS) 14 was made out of 1
11 inch stainless steel tube and compression fittings. The looped
12 system had 13 TF10FC nozzles 15, manufactured by Bete Fog Nozzle,
13 Inc. The nozzles have a 120° degree full cone mist pattern. The
14 brass nozzles had 1/4 inch male pipe connections. The WSCS was
15 located in the compartment overhead just below the overhead
16 stiffeners. Water for the WSCS was supplied by a 1 1/2 inch standpipe
17 connection 16 to the firemain (not shown). The WSCS Application
18 Rate (WSCSAR) for Class A fires (Grimwood, Paul T., *FOG Attack*, FMJ
19 International Publications Ltd., United Kingdom, 1992, p. 88., the
20 entirety of which is incorporated herein by reference for all
21 purposes) was determined by:

22
23
$$\text{WSCSAR (gpm)} = \text{Compartment Volume (ft}^3\text{)} / 270$$

24

25 This WSCSAR was then doubled for Class B fires. *U.S. Navy Salvage*

1 Ship Manual; Volume 3 (Firefighting and Damage Control), S0300-A6-
2 MAN-030, August 1, 1991, pp. 3-35, the entirety of which is
3 incorporated herein by reference, for all purposes. For a Class B
4 fire in a compartment volume of 13000 ft³, the WSCSAR is 96 gpm.
5 The WSCS flow rates were controlled by the firemain pressure.
6 Using the system of the present invention, the WSCSAR according to
7 the above equation was far greater than that actually required.
8 Thus, in Example 1, the system delivered 60 gpm at 80 psi, about
9 63% of the 96 gpm recommended according to the above equation.

10
11 The conditions in Example 1 are summarized below:

- 12 • WSCS Application Rate = 0.005 gallons per minute per floodable
- 13 volume (gpm/ft³)
- 14 • WSCS Initiation Time = 60 seconds prior to agent discharge
- 15 • WSCS Application Duration = 120 seconds
- 16 • Droplet Size = 100 - 200 microns in diameter
- 17 • Nozzle Type = 120 degree full cone water mist nozzles (Bete
- 18 Fog Nozzle, Inc. Type TF10FC or equivalent)
- 19 • Size System (number of tiers) - 1 tier system
- 20 • Nozzle Coverage (number of nozzles) = 55 ft² of floor area per
- 21 nozzle (13 nozzles)
- 22 • Activation Method = Manual
- 23 • Water Source: Firemain/Standpipe connection

24 25 INSTRUMENTATION

26 The suppression agent discharge systems were instrumented to
27 measure temperature and pressure at each of the 4 nozzles as well
28 as 2 locations in the piping. Pressures were also measured at one
29 cylinder valve and check valve on the manifold. One bottle was
30 attached to a load cell to measure mass loss. In addition, the

1 test space was instrumented to measure gas, fire and bulkhead
2 temperatures. Compartment and fuel pressures were also monitored.
3 A continuous gas sampling system measured oxygen, carbon dioxide,
4 carbon monoxide, and agent concentration at 2 locations in the
5 space, and in the supply and acid exhaust ducts. Grab samples were
6 taken at specified times and locations during each test. One type
7 of grab sample (4 locations) was analyzed using a Gas Chromatograph
8 (GC) to determine agent, oxygen, carbon dioxide and carbon monoxide
9 concentrations. The other type of sample (4 locations) was
10 analyzed using an Ion Chromatograph (IC) to quantify the
11 concentration of halide acids in the space. Seven continuous acid
12 analyzers (CAA) were also used at different locations in the
13 compartment for "real-time" measurements of acids via
14 electrochemical cells.

15 16 FIRES AND TEST SCENARIOS

17 There were 3 fire locations in the machinery space. Table 1
18 lists the fire specifications used for the Phase 2 tests described
19 in the paper. In addition, to the three main fires there were 17
20 telltale fires (about 3 kW each) located throughout the
21 compartment.

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

Table 1: Fire Specifications

Fire	Pan Size (m x m)	Pan Area (m ²)	Pan Fire Size (MW)	F-76 Diesel Spray Flow Rate (lpm)	F-76 Diesel Spray Fire Size (MW)
1	2.44 x 0.91	2.23	4.5 ^a	5.7 - 7.9	3.3-4.7 ^a
2	-	-	-	0.7 - 0.8	0.09-0.1
4	-	-	-	0.7 - 0.8	0.09-0.1

a - The pan fire preburn just overlapped the spray fire preburn in time.

TEST SERIES

The Phase 2 testing consisted of seven series of tests. Series' particulars are listed in Table 2 and particulars for the tests analyzed in this paper are listed in Table 3. Fire suppression tests used HFP at 10.1% design concentration (Series 3-5), or Halon 1301 at 5.2% design concentration (Series 6).

RESULTS

Fire Suppression and Reignition Prevention

All fires were extinguished for each scenario tested. A preliminary summary of Series 3-6 test results is shown in Table 3. These data are based on visual observation of IR video. Reignitions were attempted at Fires 2 and 4. The attempts were performed every minute until a successful reignition occurred.

1 No attempts were made after the first 5 minutes of venting.
2 Preliminary results indicate that WSCS introduction prior to
3 agent discharge as well as during the venting enhances reignition
4 protection. Also, at the agent design concentrations tested
5 Halon 1301 provided better reignition protection than HFP.

6 Although there was no dramatic difference in overhead
7 relative temperature decreases (see the section below on
8 Temperature Reduction) between Tests 4.2 and Test 3.6 (no WSCS),
9 the introduction of the WSCS during venting prevented a sustained
10 reignition (Test 3.6) and resulted in only a brief reignition
11 lasting 3 seconds.

12 13 Temperature Reduction

14 WSCS Not Used

15 Fig. 2 shows the measured temperatures from the aft
16 thermocouple tree during Test 3.6. The introduction of the agent
17 in the compartment (flash cooling) and the suppression of the
18 fires reduced the ambient temperatures. The maximum measured
19 temperature (aft thermocouple tree) did not decrease to 100°C
20 until 180 seconds after agent discharge initiation.

21 22 WSCS Initiated At Same Time As Agent Discharge

23 For Test 4.5 (Fig. 3) the WSCS was initiated simultaneously
24 with the gaseous agent discharge. The WSCS was run for 60
25 seconds at a WSCSAR of 60 gallons per minute (gpm). Within 40

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 seconds after discharge initiation all aft thermocouple tree
2 temperatures were below 50°C. The cooling effect of the WSCS is
3 clearly visible.
4

5 WSCS Initiated Before Agent Discharge

6 During Test 5.2 the WSCS was initiated 60 seconds before
7 agent discharge for a 120 seconds application, and at 780 seconds
8 after discharge initiation for a 60 seconds application. Fig 4
9 shows the measured temperatures from the aft thermocouple tree.
10 The peak temperature from the aft thermocouple tree was measured
11 320°C just prior to WSCS activation. The most dramatic
12 temperature reduction is observed in the upper level of the
13 compartment. At agent discharge (60 seconds after WSCS
14 initiation) the peak measured temperature was 60°C. Within 20
15 seconds after agent discharge initiation the measured aft
16 thermocouple tree temperatures were all below 40°C. In a real
17 shipboard fire, the introduction of the water spray prior to
18 agent discharge would drastically limit flame spread and reduce
19 damage by reducing compartment temperature. Similar WSCS
20 effectiveness is expected when used with other halon-like agents.
21

22 WSCS Initiated After Agent Discharge

23 The effects on compartment temperature of the WSCS
24 initiation after fire suppression are demonstrated in Test 4.2
25 (Fig. 5). For this test the first WSCS application was initiated

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 300 seconds after agent discharge initiation and lasted 60
2 seconds. A second application, for 120 seconds, was initiated
3 simultaneously with compartment venting at 900 seconds. The
4 first WSCS application reduced overhead temperature from 70°C to
5 below 40°C with 20 gallons of water within 20 seconds. The
6 second WSCS application, in conjunction with the venting, reduced
7 the temperature from 35°C, to below 25°C within 20 seconds
8 compared to a decrease from 65°C to below 55°C in 100 seconds for
9 Test 3.6 (no WSCS used).

10
11 **HF Generation and Mitigation**

12 WSCS Not Used

13 The reported peak measured values are from one of the
14 Continuous Acid Analyzers (CAA) located in the upper level of
15 the compartment. HF values for HFP tests without the WSCS were
16 5000 parts per million (ppm) for Test 3.6 and 4100 ppm for Test
17 4.2. For the Halon 1301 Test 6.1 the measured peak was 1100 ppm.
18 The higher HF generated values associated with HFP are consistent
19 with Phase 1 testing.

20
21 WSCS Initiated At Same Time As Agent Discharge

22 The initiation of the WSCS at the same time as agent
23 discharge (Test 4.5) limited HF generation to a peak value of
24 1800 ppm, compared to values over 4000 ppm for tests without
25 WSCS.

1 WSCS Initiated Before Agent Discharge

2 The initiation of the WSCS one minute prior to agent
3 discharge (Test 5.2) limited HF generation to a peak value of 200
4 ppm (Fig. 6), compared to values over 4000 ppm for tests without
5 WSCS. Similarly for Halon 1301, for Test 6.2 (with WSCS
6 initiation at -60 seconds) peak HF recorded value was 200 ppm
7 compared to 1100 ppm for the test without the WSCS. This drastic
8 drop in HF peak values is a result of flame inhibition and lower
9 flame temperatures resulting from the oxygen displacement
10 associated with the conversion of water to steam and the reduced
11 compartment air temperatures.

12
13 WSCS Initiated After Agent Discharge

14 The capability of the WSCS to scrub or remove HF from the
15 air was examined during Test 4.2 where the WSCS was initiated 300
16 seconds after agent discharge. The HF concentration drop at 300
17 seconds in Fig. 7 illustrates the WSCS acid scrubbing
18 performance.

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

Table 2: Test Series Overview

Series No.	Agent	Discharge System	Number of Nozzles	Fires	WSCS Application			Hold Time (time prior to venting) (min)
					Before Agent Discharge	During Agent Discharge	Prior/ During Venting	
1	No	No	No	Yes	No	No	No	-
2	HFP	Standard Navy	4,8	No	No	No	No	30
3	HFP	Standard Navy	4	Yes	No	No	No	5, 15, 30
4	HFP	Standard Navy	4	Yes	No	Yes	Yes/No	15
5	HFP	Standard Navy	4	Yes	Yes	Yes	Yes/No	15
6	Halon 1301	Standard Navy	4	Yes	Yes/No	Yes/No	Yes/No	15
7	HFP	Modified ^a	4	No	No	No	No	30

a - Larger cylinder valve, flexible hose, and check valve compared to Standard U.S. Navy hardware.

Docket No.: N.C. 77,714
 Inventor's Name: Sheinson et al.

PATENT APPLICATION

1

Table 3: Test Results for HFP Tests Series 3-5 and Helon 1301 Tests Series 6

Test No.	WCS Initiation (min:sec) (t=0 @ discharge) and Duration (min:sec)				WCSAR (gpm)	Fire Extinguishment Times (min:sec) *			Peak HF Conc (ppm)	Agent Conc. at Fire 1 @ 5 and 15 sec. (%)	Peak Comp. Temp. @ Venting Initiation (°C)	First Successful Sustained Reignition* (Venting Initiated @ 15.00 min)	
	First Application		Second Application			1	2	4				Fire 2	Fire 4
	Initiation	Duration	Initiation	Duration									
1.16b	N/A	N/A	N/A	N/A	N/A	d	d	d	N/A	N/A	N/A	N/A	N/A
3.6	N/A	N/A	N/A	N/A	N/A	0:10	0:09	0:04	5000	4.4/8.9	70	No	17:00
4.2	5:00	1:00	15:00	2:00	60	0:09	0:12	0:08	4100	3.8/10.5	40	e	N/A
4.5	0:00	1:00	N/A	N/A	60	0:09	0:11	0:16	1800	3.5/10.2	50	No	17:00
5.2	-1:00	2:00	13:00	1:00	60	0:07	0:05	0:04	200	3.2/9.3	40	e	16:00
5.3	-2:00	3:00	N/A	N/A	60	0:08	0:05	0:36	1300	4.6/g	f	No	17:00
5.4	-1:00	2:00	15:00	2:00	40	0:09	0:12	0:07	2000	g	f	No	18:00
6.1	N/A	N/A	N/A	N/A	N/A	0:09	0:11	0:06	1100	g	f	No	18:00
6.2	-1:00	2:00	15:00	2:00	60	-0:06	0:04	0:06	200	g	f	No	19:00

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

- 1 a - Times are determined from visual observations of IR video.
- 2 b - HF peaks from Continuous Acid Analyzers.
- 3 c - Reignitions attempted for the every minute from agent discharge until a successful
- 4 reignition was achieved, up to 5 minutes after venting initiation.
- 5 d - Fuel to spray fires was secured 10 seconds after discharge initiation would have occurred
- 6 (control fire- no suppression agent used).
- 7 e - None attempted due to equipment failure.
- 8 f - Data currently being processed.
- 9 g - Data not available.
- 10
- 11
- 12
- 13

Results

14 Results show that the innovative WSCS usage significantly
15 reduced compartment temperatures. Overhead temperature was
16 reduced from over 250°C to less than 60°C in less than 5 seconds
17 from WSCS/agent discharge initiation. For comparison, the
18 overhead temperature over the same interval dropped only 50°C
19 with agent discharge alone. Results also showed that the WSCS
20 dramatically reduced HF generation as well as accelerated the
21 acid decay rate.

22 Phase 2 preliminary results show that the employed WSCS is a
23 viable option for rapid reduction of compartment temperature.
24 The low water pressure WSCS tested provided very rapid
25 compartment temperature reduction in 15 seconds with less than 20
26 gallons of water. The ability of the WSCS to run off the ship's
27 firemain or from its own pressurized water tank make it a viable
28 system for shipboard installation.

29 Compartment reclamation initiation is a function of fire
30 suppression, reignition potential, compartment temperatures and

Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION

1 atmospheric acid product concentrations. The firefighting team
2 reentry and compartment reclamation procedures depend on the
3 particulars of a fire scenario: type of space, contents, and fire
4 suppression system. Results show that the WSCS significantly
5 reduced compartment temperatures and is particularly effective
6 when initiated before agent discharge. The compartment
7 temperature reduction as well as the reduced HF generation and
8 subsequent mitigation concentration make the WSCS a viable
9 supplement to a gaseous suppression system. Also, WSCS can
10 enhance a gaseous agent's reignition protection and hence render
11 the compartment safer during reentry and desmoking /venting.
12

13 Obviously, many modifications and variations of the present
14 invention are possible in light of the above teachings. It is
15 therefore to be understood that

16 the invention may be practiced otherwise than as
17 specifically described.


Docket No.: N.C. 77,714
Inventor's Name: Sheinson et al.

PATENT APPLICATION


ABSTRACT

A water spray mist is used to cool a compartment fire before discharge of a gaseous fire suppression. As a result, less water and less fire suppression agent is needed than required with conventional method of suppressing compartment fires. The water spray may be continued for a short time after initial discharge of the fire suppression agent, and may be restarted after the fire has been extinguished. Also, the present invention reduces the levels of toxic and corrosive gases in compartment created during the suppression of compartment fires by the use of a gaseous fire suppression agent.


1




HFP Fire Suppression Temperature Profiles



HFP/WSCS Fire Suppression Temperature Profiles



HFP/WSCS Fire Suppression Temperature Profiles




Time (seconds: agent discharge @ $t = 0s$)
(WSCS Initiated @ $t = -60s$ for 120s & $+780s$ for 60s)

Thermocouple Trace: 6-27-1
ex-US8 SHADWELL
Phase 2, Test 6.2

Figure 4

HFP/WSCS Fire Suppression Temperature Profiles




Time (seconds: agent discharge @ $t = 0s$)
(WSCS Initiated @ $+300s$ for 60s & $+900s$ for 120s)

Thermocouple Trace: 6-27-1
ex-US8 SHADWELL
Phase 2, Test 4.2

Figure 5

HFP Fire Suppression Hydrogen Fluoride Profile




Time (seconds: agent discharge @ $t = 0s$)
(WSCS Initiated @ $t = -60s$ for 120s & $+780s$ for 60s)

Figure 6

HF Analyzer: 4-22-3
60-485 SHADWELL
Phase 2, Test 6.2

HFP Fire Suppression Hydrogen Fluoride Profile



Time (seconds: agent discharge @ $t = 0s$)
(WSCS Initiated @ $t = +300s$ for 60s & $+900s$ for 120s)

Figure 7

HF Analyzer: 4-22-3
60-485 SHADWELL
Phase 2, Test 4.2